



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER SUPPLY

Nashville Environmental Assistance Center
537 Brick Church Park Drive
Nashville, Tennessee 37243-1550

April 4, 2000

Mr. Gene Johnson
Director, Dickson Water System
206 West Chestnut Street
Dickson, Tennessee 37055

RE: Plant Classification
Dickson Water System
PWSID #0000191
Dickson County

Dear Mr. Johnson:

The Dickson Water System's water treatment facility has been classified by the Division of Water Supply as a "Water Treatment-3" facility. A recent review of the facility's design capacity, nature of the raw water, treatment techniques employed at the facility, chemical feed operations, and laboratory practices, has indicated that the classification should be upgraded. Classification of water treatment facilities is determined by the Division using a scoring system based primarily upon the above referenced criteria. Based upon a classification score of sixty-seven (67), the Dickson Water System water treatment facility is hereby upgraded to the classification of "Water Treatment-4". The effective date of this change is April 1, 2000.

If you have any questions and/or comments concerning this matter, contact David Sizemore at (615) 650-7283 or myself at (615) 650-7243.

Sincerely,

Louis K. Burnett
Manager, Division of Water Supply
Nashville Environmental Assistance Center

xc: Central Office
Mr. Bruce Trotter, Dickson Water System
file